


Leaks can be detected from space

Summary of Pilot project









Comparing Utilis date with leak history

Utilis ID	Street	Number	Code	City
01414	Noémi utca	15	1028	Budapest
01420	Dózsa György útca	105	1224	Budapest
01450	Kártya utca	2	1221	Budapest


3/36

Field Verification Summary Report

Finding Type	Total
Leak	10
Unverified	2
Quiet	4

Leaks per day: 5






01416 – leaking hydrant

01417- leaking hydrant







01418 – leak on service Estimated 8 l/m

01410 - leak on main







01411 – leaking hydrant valve Estimated 30 l/m

01452 – leaking hydrant valve Estimated 0.1 l/m






01452 - leaking hydrant valve




01444 – leak on service fixed 2 weeks ago





01439 – leaking hydrant



01439 – leaking drinking fountain

Unverified — there is still a chance for a leak



01413 – no access to 500mm pipe



01433 – no access to 200mm pipe, runs under train – recommend further investigation



GPR Pressure test/helium test



Create additional access points

Transmission mains – Big diameter

- Limited access points
- Big diameter not good acoustics
- No one will complain

Utilis can act as a guide to begin and learn this field and try to prepare analysis and assessment plans for these pipes



Kansas City, USA March 2017



Australia November 2016



Lets do some math...

Facts:

Volume of water: 162,802,000m³

Volume of revenue water: 137,189,000m³

NRW: 25,613,000m³

*annual report 2015

Physical loss (50% of NRW) = $\frac{12,000,000m^3}{12,000,000m^3}$ (estimated 8%)



Utilis: zero means zero



Unavoidable background leakage rates

Infrastructure Component	Background Leakage at ICF=1.0	Units
Mains	9.6	liter per kilometer of mains per day per meter of pressure
Service Connection – main to curb-stop	0.6	liter per service connection per day per meter of pressure
Service Connection – curb-stop to customer meter	16	liter per kilometer of service connection per day per meter of pressure

Source: Lambert et al. 1999


UBL in Budapest = 4,040,579 m³ p.a.

Today this number = 0 (base line) Utilis is looking to lower the UBL


Mains length	5,700
Wanis length	3,700
Pressure	49
Service connections	240,000
Length of Service connections	1,700



Mínimum Night Flow – Bring it down to Zero







Utilis:

"finding and fixing leaks faster than they reappear is a key for water loss reduction"



Our offer – test Utilis over 1 year (extended pilot)

Step by step:

- 1. Choose several DMAs (about 2000KMs)
- 2. Create together a platform for safe data management of this project
- 3. Schedule to scan these DMAs 3 times per year
- 4. Before each scan check MNF or water balance over past month
- 5. <u>Dedicate and certify an acoustic team for Utilis work</u>
- 6. Fix all leaks found by acoustic team/estimate annual size
- 7. After every scan measure MNF or water balance over next month to compare with previous measurements
- 8. Summarize and make calculations for multi annual engagement in Budapest as well as 3rd party projects

